

# CERTIFICATE

## EN 927-2

No. 2004437-391



**DANISH  
TECHNOLOGICAL  
INSTITUTE**

Gregersensvej  
DK-2630 Taastrup  
Tel. +45 72 20 20 00  
Fax +45 72 20 20 19

info@teknologisk.dk  
www.teknologisk.dk

**Certificate  
Holder:**

**Teknos A/S  
Industrivej 19  
DK-6580 Vamdrup  
Denmark**

**Material:**

**TEKNOL AQUA 1410-01 Colourless (80-100) g/m<sup>2</sup>  
ANTISTAIN AQUA 5200 Opaque (189-231) g/m<sup>2</sup>  
AQUATOP VIRTA Opaque (162-198) g/m<sup>2</sup>**

**Substrate  
EN 927-3:  
Exposure  
EN 927-3:**

**Scotch pine (Pinus sylvestris L.).  
45° facing south  
The exposure conditions are rated as 'Severe'**

**Conclusion:**

**The system is classified as 'Stable'**

**Method(s):**

Test according to:  
EN 927-5:2023. *Paints and varnishes - Coating materials and coating systems for exterior wood - Part 5: Assessment of the liquid water permeability.*  
and  
EN 927-3:2019. *Paints and varnishes - Coating materials and coating systems for exterior wood - Part 3: Natural weathering test.*

Assessment according to:  
EN 927-2:2022. *Paints and varnishes - Coating materials and coating systems for exterior wood - Part 2: Performance specification.*  
and  
EN 927-1: 2013. *Paints and varnishes - Coating materials and coating systems for exterior wood - Part 1: Classification and selection.*

**Report No(s):**

EN 927-5: Report no.: 214938-253 dated 28-06-2024  
EN 927-3: Report no.: 2419338-14 dated 20-06-2025

**Date/place  
Signature:**

Benjamin Noufel  
Mobil: +45 7220 1706  
E-mail: [bnou@dti.dk](mailto:bnou@dti.dk)

Test responsible

Sofie Brandt Hansen  
Mobil: +45 7220 1761  
E-mail: [sbrh@dti.dk](mailto:sbrh@dti.dk)

Co-responsible



DIGITALT SIGNERET DOKUMENT

23. juli 2025

TEKNOLOGISK INSTITUT

