

CERTIFICATE

EN 927-2

No. 2004437-406



DANISH
TECHNOLOGICAL
INSTITUTE

Gregersensvej
DK-2630 Taastrup
Tel. +45 72 20 20 00
Fax +45 72 20 20 19

info@teknologisk.dk
www.teknologisk.dk

**Certificate
Holder:**

**Teknos A/S
Industrivej 19
DK-6580 Vamdrup
Denmark**

Material:

**TEKNOL AQUA 1414-01 Colourless (80-110) g/m²
ANTISTAIN AQUA 5200 Opaque (189-231) g/m²
AQUATOP VERTA Opaque (162-198) g/m²**

**Substrate
EN 927-3:**

Scotch pine (*Pinus sylvestris* L.).

**Exposure
EN 927-3:**

**45° facing south
The exposure conditions are rated as 'Severe'**

Conclusion:

The system is classified as 'Stable'

Method(s):

Test according to:

EN 927-5:2023. Paints and varnishes - Coating materials and coating systems for exterior wood - Part 5: Assessment of the liquid water permeability.
and

EN 927-3:2019. Paints and varnishes - Coating materials and coating systems for exterior wood - Part 3: Natural weathering test.

Assessment according to:

EN 927-2:2022: Paints and varnishes - Coating materials and coating systems for exterior wood - Part 2: Performance specification.
and

EN 927-1: 2013: Paints and varnishes - Coating materials and coating systems for exterior wood - Part 1: Classification and selection.

Report No(s):

EN 927-5: Report no.: 214938-325 dated 28-06-2024

EN 927-3: Report no.: 214938-86 dated 20-06-2025

Date/place

Signature:

Benyamin Noufel
Mobil: +45 7220 1706
E-mail: bnou@dti.dk

Test responsible

Sofie Brandt Hansen
Mobil: +45 7220 1761
E-mail: sbrh@dti.dk

Co-responsible



DIGITALT SIGNERET DOKUMENT

23. juli 2025

TEKNOLOGISK INSTITUT



DANAK
TEST Reg.no. 2