



TEST CERTIFICATE

EN 599-1

Number 2012-01

MPA | Eberswalde **CERTIFICATE HOLDER:**

Teknos A/S
Industrivej 19
DK-6580 Vamdrup

The product


GORI 356 (FSPJ-C-28-2)

has sufficient efficacy against wood destroying basidiomycetes for Use Class 2 and 3 under top coat.

Application rate: 44 g/m²

**The product fulfils the requirements of EN 599-1 (07/2009):
Durability of wood and wood-based products - Efficacy of preventive wood
preservatives as determined by biological tests –
Part 1: Specification according to use class**

MPA Eberswalde
Material Testing Institute Eberswalde, Germany
2012-12-04, valid until October 2018


Dr. Peter Schumacher
Head of institute




Dr. Eva-Maria Fennert
Specialist

The evidence of the biological effectiveness of GORI 356 (FSPJ-C-28-2) against wood destroying basidiomycetes is provided by the following test reports:

1. MPA test report Nr. 32/03/8510/01 of 2004-05-24, Determination of protective effectiveness against wood destroying basidiomycetes according to EN 113 (1996) without accelerated ageing procedure
2. MPA test report Nr. 32/03/8510/02 of 2004-06-21, Determination of protective effectiveness against wood destroying basidiomycetes according to EN 113 (1996) after leaching procedure according to EN 84 (1997)
3. MPA test report Nr. 32/03/8510/03 of 2004-09-09, Determination of protective effectiveness against wood destroying basidiomycetes according to EN 113 (1996) after evaporative ageing procedure according to EN 73 (1988)
4. MPA test report Nr. 32/04/8510/05 of 2006-11-06, Determination of protective effectiveness against wood destroying basidiomycetes according to EN 113 (1996) after evaporative ageing procedure according to EN 73 (1988)