

Teknos Oy P.o.Box.107 00371 Helsinki

The following coating system for concrete constructions has been tested by VTT (Technical research centre of Finland) according to the following instructions and standards:

- STUK-YTO-TR-210: 2017. *Requirements for coatings of nuclear power plant containments.*
- ASTM D 3911 16, 2016. Standard test method for evaluating coatings used in lightwater nuclear power plants at simulated design basis accident (DBA) conditions.
- ASTM D 4082 10, 2010. Standard test method for effects of gamma radiation on coatings for use in nuclear power plants. \*
- ISO 8690, 1988. Decontamination of radioactively contaminated surfaces Method of testing and assessing the ease of decontamination.

Coating system	INERTA 280 A,	1 x 500 µm
	Total DFT	500 µm
Manufacturer	Teknos Oy	

According to test results, this coating system fulfils the requirements given in 2017 by Radiation and Nuclear Safety authority of Finland (STUK) for Radiation (gamma) and DBA-resistance and Ease of decontamination. Full experimental details have been given in report VTT-R-00254-20.

\*) The total accumulated dose was  $1 \times 10^8$  rads (=  $1 \times 10^6$  J/kg =  $1 \times 10^6$ Gy) and the dose rates were greater than the regulator required.

Espoo, 07.12.2020

Pasi Väisänen Pasi Väisänen Pasi Väisänen

Engineer

DocuSianed by: Sami Reg

Sami Penttilä Research Team Leader

Tel. +358 20 722 111 Fax +358 20 722 7001