

Teknos Oy P.o.Box.107 00371 Helsinki

The following coating system for steel constructions has been tested by VTT (Technical research centre of Finland) according to the following instructions and standards:

- STUK-YTO-TR 210: 2004. Requirements for coatings of nuclear power plant containments.
- ASTM D 3911 95, 1995. Standard test method for evaluating coatings used in lightwater nuclear power plants at simulated design basis accident (DBA) conditions
- ASTM D 4082 95, 1995. Standard test method for effects of gamma radiation on coatings for use in light-water nuclear power plants. *
- ISO 8690, 1988. Decontamination of radioactively contaminated surfaces Method of testing and assessing the ease of decontamination.

Coating system INERTA PRIMER 5 A, 1 x 60 μm

INERTA 270 A, 1 x 140 μm

Total DFT 200 μm

Manufacturer Teknos Oy

According to test results, this coating system fulfils the requirements given in 2004 by Radiation and Nuclear Safety authority of Finland (STUK) for Radiation (gamma) and DBA-resistance and Ease of decontamination. Full experimental details have been given in report VTT-R-03684-16.

*) The total accumulated dose was $1x10^8$ rads (= $1x10^6$ J/kg = $1x10^6$ Gy) and the dose rates were greater than the regulator required.

Espoo, 07.12.2020

Pasi Vaisauun Pasi Vaisauun Pasi Väisänen Engineer DocuSigned by:

4419E54C702A444...

Sami Penttilä

Research Team Leader